



Certificate of Compliance

Certificate: 2715424

Master Contract: 242147

Project: 2715424

Date Issued: April 17, 2014

Issued to: Jogler LLC

6646 Complex Dr
Baton Rouge, LA 70809
USA
Attention: Brandon Harper

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Jignesh Dabhi

Issued by: Jignesh Dabhi

PRODUCTS

CLASS 9098 81 - MISCELLANEOUS - For Hazardous Locations - Certified to US Standards

CLASS 9098 01 - MISCELLANEOUS - For Hazardous Locations

Class I, Div 1, Groups B, C and D; Class I Div 2 Group A, B, C and D; Class II Div 1 Group E, F and G; Class III; T4A, Tamb -40°C to 105°C; Type 4X

Magnetic level switch model JS 10 series- 150VDC, 1A, 25W; 130VAC, 0.2A max/ 230VAC, 0.1A max

Magnetic level switch model JS 30 series- 150VDC, 3A, 75W; 120VAC, .625 A max; 25VAC, 3A 75; 240VAC 0.3125A

JS10 and JS30 configurations:

JS-ab-c-d

Where,

a is current rating: Where 1 is for 1Amp(JS 10 series); 3 is for 3Amp (JS 30 series)



Certificate: 2715424

Master Contract: 242147

Project: 2715424

Date Issued: April 17, 2014

b is number of reed switches: Where 1 is for 1 switch (SPDT configuration); 2 is for 2 switches (DPDT configuration)

c is enclosure: Where A is for Epoxy coated aluminum enclosure; S is for Stainless steel enclosure; 0 is for Switch housing without enclosure

d is mounting: 0, H or R for different mounting options.

APPLICABLE REQUIREMENTS

C22.2 no 0-10	General Requirements
C22.2 no 14-13	Industrial Control Equipment- Twelfth Edition
C22.2 no 213-M1987	Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
C22.2 no 30-M1986 (R2012)	Explosion-proof Enclosures for Use in Class I Hazardous Locations.
UL 508, 17th Edition	Industrial Control Equipment.
ISA 12.12.01-2013	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.
UL 1203, 5th edition	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 2715424

Master Contract: 242147

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2715424	Apr 17, 2014	Certification of JS-10 and JS-30 series magnetic level switches for Class I Div 1, Groups B, C and D; Class I Div 2 Group A, B, C and D; Class II Div 1 Group E, F and G, Class III; T4A, Tamb -40°C to 105°C; Type 4X.